

130

**VIA CERTIFIED MAIL**  
(Return Receipt Requested)

August 5, 2010

REC'D  
AUG 16 2010  
APCO

Ms. Rebecca Webber  
Director, Air and Waste Management Division  
U.S. Environmental Protection Agency  
901 N. 5th Street, Kansas City, KS 66101

Mr. James Kavanaugh, Director  
Air Pollution Control Program  
Missouri Department of Natural Resources  
PO Box 176  
Jefferson City, MO 65102

RE: NESHAP Initial Notification  
Malden Municipal Power and Light  
County Number: 069  
Plant Number: 0034  
NAICS Code: 221112

Dear Ms. Webber and Mr. Kavanaugh:

On March 3, 2010, the United States Environmental Protection Agency adopted final amendments to the National Emission Standards for Hazardous Air Pollutants for Reciprocating Internal Combustion Engines, 40 C.F.R. Part 63 Subpart ZZZZ. These amendments were effective on May 3, 2010. Pursuant to Section 63.6645(a) and Section 63.9(b), City of Malden submits the following information as its Initial Notification:

1. Name and address of the owner/operator:  
City of Malden  
111 East Laclede Street  
Malden, MO 63863  
(573)-276-2238
2. Address of the affected source (*i.e.* the physical location of the engine(s) subject to Subpart ZZZZ):  
405 South Beckwith  
Malden, MO 63863

Ms. Rebecca Webber  
Mr. James Kavanaugh  
August 13, 2010  
Page 2

3. Identification of the relevant standard and compliance date: Subpart ZZZZ standards for existing RICE at area sources and May 3, 2013.
4. Description of the affected source:

Engine #1:	Fairbanks Morse	33F16	802 HP
Engine #2:	Caterpillar	3516	2628 HP
Engine #3:	Caterpillar	3516	2628 HP
Engine #4:	Caterpillar	3516	2628 HP
Engine #5:	Fairbanks Morse	38DD8-1/8	1920 HP
Engine #6:	Fairbanks Morse	38TDD8-1/8	2880 HP
Engine #7:	Fairbanks Morse	38TDD8-1/8	4000 HP
Engine #8:	Pielstick	12PC2DF	6000 HP
5. Types of HAPs emitted by affected source: Benzene, toluene, xylenes, 1,3-butadiene, formaldehyde, acetaldehyde, acrolein, some polycyclic aromatic hydrocarbons and other trace organic compounds.
6. Major or Area Source: Area.

City of Malden also operates RICE at the facility that are exclusively used for emergencies. These RICE are not required to be included in the Initial Notification pursuant to 40 C.F.R. § 63.6645(a)(5).

If you have any questions regarding the above, please do not hesitate to contact

Verbal Blakey  
Consulting Engineer  
BHMG Engineers, Inc.  
630 Jeffco Blvd  
Arnold, MO 63010  
(636) 296-8600

Sincerely,  
City of Malden



Honorable Ray Santie, Mayor

pc: BHMG Engineers, Inc.